



Energising Quality

**GENERAL CLARIFICATION AGAINST TENDER FOR**  
**SUPPLY, INSTALLATION, TESTING AND COMMISSIONING**  
**OF**  
**UPS SYSTEM**  
**FOR**  
**SECTION-10 & 11 UNDER NORTH EAST GAS GRID PHASE-III PROJECT OF IGGL**  
**Tender No.: C221052-VCS-IGGL-TENDER-004 Dated 29.08.2022**

Date : 22.09.2022

TENDER ID: VCS21000025

Project : NORTH EAST GAS GRID PHASE-III OF IGGL

Owner : INDRADHANUSH GAS GRID LIMITED (IGGL)



Sl. No.	Description	Details
1	GENERAL CLARIFICATION	This is to clarify that the winding of I/O transformers/chokes of UPS System shall be <b>Copper Wound</b> . Bidders to submit their bids accordingly on or before due date 26.09.2022 (upto 1400 hours IST).

**Notes:**

1. All other terms & conditions of tender document remain unaltered.
2. This General Clarification issued shall be an integral part of tender document.
3. Bidder to submit signed & stamped copy of this General Clarification along with their Un-Priced bid as a token of acceptance.