

BIDDER'S QUERIES FOR PRE BID MEETING

To,

M/s INDRADHANUSH GAS GRID LIMITED
7th Floor, 122A, NRL Centre, Christian Basti, G. S. Road, Guwahati-781006, Assam

SUB: Pre-bid Queries

TENDER NO: C221052-VCS-IGGL-TENDER-005

SL. NO.	REFERENCE OF BIDDING DOCUMENT				BIDDER'S QUERY	VCS/IGGL'S REPLY
	SEC. NO.	Page No.	Clause No.	Subject		
1.	SOR				In the SOR for MPPT charger ratings are mentioned differently in Supply portion and Installation portion. Please confirm the actual one.	Refer Corrigendum-I
2.	Vol-II	15	4.0	Supply of Material	For 20kWp system, if there will be any transport to grid. Suppose if we could not able to use the power for one day then it will be goes to grid where unidirectional meter does not know about the energy direction and it will add the billing for export and causes energy charges. Please Clarify.	No transport of energy to grid is envisaged for this project. The inverter shall have appropriate arrangement to prevent the surplus power from flowing into the unidirectional meter.
3.	Vol-II	10	5.2	Other Miscellaneous Works	For 20kW ongrid systems, Netmetering if exists. Define Scope of netmetering.	Refer Clause 5.2.

SIGNATURE OF BIDDER: _____

NAME OF BIDDER: _____