



INDRADHANUSH GAS GRID LIMITED (IGGL)

(Joint Venture of IOCL, ONGC, GAIL, OIL and NRL) **GUWAHATI, ASSAM**

NORTH -EAST GAS GRID PIPELINE PROJECT

REPLY TO PRE BID QUERIES FOR

ANNUAL RATE CONTRACT 2(TWO) YEARS BASIS FOR SUPPLY & INSTALLATION OF METERING SKIDS & ASSOCIATED FACILITIES

OPEN DOMESTIC COMPETITIVE BIDDING

Tender No.: 05/51/23VC/IGGL/030

Visit: www.tenderwizard.com/MECON (Tender wizard helpdesk: 011-49424365)



PREPARED AND ISSUED BY

MECON LIMITED

(A Govt. of India Undertaking) Delhi, India



REPLY TO BIDDERS QUERIES

ANNUAL RATE CONTRACT 2(TWO) YEARS BASIS FOR SUPPLY & INSTALLATION OF METERING SKIDS &

ASSOCIATED FACILITIES UNDER NORTH EAST GAS GRID PIPELINE PROJECT OF M/s IGGL Tender Doc. No.: 05/51/23VC/IGGL/030



DATED: 10.03.2023 S.N. CL. No. Section/ Clarification / Deviation Section Detail/Description MECON's Reply Page Special Instruction to Page no. 153 Velocity through the Turbine meter shall be restricted to 20m/s. Furnish the We understand that turbine meter type test approval shall be as per of 626 vendor for Turbine sizing calculation with offer, Meter shall be designed as per AGA-7, OIML EN12261 and certificate for the same must be furnished as per legal & W & flow meter doc no.: recommendation M guidelines. Please confirm MEC/05/E5/TFM-SIV Turbine flow meter Tender Condition Prevails. clause no.: 1 Special Instruction to Page no. 153 The turbine meter shall be suitable for the area classification IEC Zone-1, Gr.we understand that certificate from international statutory body, i.e. ATEX vendor for Turbine of 626 IIA & IIB, T3, Certificates from statutory bodies for Hazardous area for intrinsically safe is acceptable. Please confirm. flow meter doc no .: classification shall be submitted along with offer MEC/05/E5/TFM-SIV Tender Condition Prevails. Turbine flow meter clause no.: 2 Datasheet of Turbine Page no. 154 Pulses suitable to respective flow computer (No. of HF & LF as per TS No.: As per TS No.: MEC/05/E5/TS/TFM-030 clause no. 17, we understand that flow meter doc no.: of 626 MEC/05/E5/TS/TFM-030) for turbine meter upto 3" one HF sensor on meter body as well as one LF MEC/05/E5/DS-TFM sensor on Index head is required and for turbine meter 4" and above, two Tender Condition Prevails. Point no.: 26 HF sensors are required on meter body. Kindly confirm Technical specification Page no. 4 of Vendor shall carry out the perfomance test and certify the meter in Since the rangeability of turbine meter required is 1:20, we understand for Turbine flow combination with its compnio electronics. A recognized test facility with that calibration at flow point 2.5% of Qmax is not to be considered as it is meter Doc no.: beyond the flow range of turbine meter complying 1:20 rangeability, traceable refernce measurment shall be used. Flow test data at 7 point .MEC/05/E5/TS/TFM-Please confirm. covering the minimum to the maximum flow rate shall be obtained for Wil be dealt during detail engineering. However, 7 ascertaining the meter linearity and repetability within the specified limits wet point calibration is mandatory. Point no. 18.4 calibration of flow meters shall be done at the following nominal rates: 0.025gmax, 0.05gmax, 0.1gmax, 0.25gmax, 0.5gmax, 0.75gmax, and gmax. Datasheet of Turbine Page 154 of Straightening vane type - REQD. we understand that turbine meter with integral straightening vane is 626 flow meter DS no.: required. Kindly confirm MEC/05/E5/DS-TFM Point: 31 External flow straightener is mandatory.



REPLY TO BIDDERS QUERIES ANNUAL RATE CONTRACT 2(TWO) YEARS BASIS FOR

SUPPLY & INSTALLATION OF METERING SKIDS & ASSOCIATED FACILITIES UNDER NORTH EAST GAS GRID PIPELINE PROJECT OF M/s IGGL




Tender Doc. No.: 05/51/23VC/IGGL/030

		DATED: 10.				
S.N.	CL. No.	Section/ Page	Section Detail/Description	Clarification / Deviation	MECON's Reply	
6		Page no. 161 of 626	4 sets of Flow computer documentation including product literature, software/Hardware manual, maintenance instructions, Modbus addressing etc shall be supplied	Please note that 4 sets of necessary documents, literature and manuals will be provided in soft copy in CD-ROM	Tender Condition Prevails.	
7		Page no. 161 of 626	The Flow computer shall be approved for Custody transfer by NMI/PTB/ renowned lab	We understand that custody transfer gas metering approval certification from NMI/ Measurement canada/PTB will be accepted as listing for renowned lab is not provided.	Tender Condition Prevails.	
8	6.4	4	datasheet of catridge filter	Kindly approve Rockwin make cartridge filter for this project.We have supplied our cartridge filter in various CGDs ,PTR enclosed for your kind considertion	Tender Condition Prevails.	
9	Notes :4	24	datasheet of catridge filter	Available calibration pressure in gail hazira lab is 46-49 kg/cm2. Therefore, we understand that wet calibration of turbine flowmeter is acceptable in GAIL hazira lab at this available pressure. Kindly confirm.	GAIL Hazira lab at available pressure is acceptable. Rest, Tender Condition Prevails.	
10			P&ID	Monitor with internal SSV is also acceptable .Kindly confirm.	Not Acceptable. Rest, Tender Condition Prevails.	
11		Technical	Skid plot plan	Request to please provide Skid plot plan with inlet and outlet orientation for each skid	It will be provided to successful bidder. Tender Condition Prevails.	
12		Technical	Size as per P&ID	We understand that USM and all main line ball valve size shall be as per P&ID for all skid. Lower size is not acceptable . Please confirm	Confirmed. Rest, Tender Condition Prevails.	



REPLY TO BIDDERS QUERIES ANNUAL RATE CONTRACT 2(TWO) YEARS BASIS FOR

NNUAL RATE CONTRACT 2(TWO) YEARS BASIS FOR SUPPLY & INSTALLATION OF METERING SKIDS &





DATED: 10.03.2023 S.N. CL. No. Section/ Section Detail/Description Clarification / Deviation MECON's Reply Page 13 We requested to accept FPD based gas chromatograph also which will measure both H2S and Total sulphur separately in single Gas FPD based is also acceptable subjected to meeting chromatograph. GC with FPD principle are globally acceptable for measuring PNGRB, other statutory requirements and tender Total sulphur and H2S in natural gas. We had supplied FPD based GC for conditions. All the consumables such as tape / carrier H2S and Total sulphur measurement in ONGC, Reliance, Adani, HSEPL etc gas / calibration gas / other gas, etc. required for 2 for which documents are attached for your reference. Hence we request to years continuous online operation is in bidder's please confirm your acceptance to consider FPD base GC for Total sulphur Technical H2S & TOTAL SULPHUR Analyzer scope. Further, all the items / accessories as with H2S analyser analyser. required considering OEM recommendations for installation in all respect shall also be provided by We also understand that Single FPD based GC is required to measure both bidder. However, analyzers, probes & tappings shall Total sulphur and H2S. be separate for each H2S, Total Sulphur, Gas Chromatograph and moisture analyzer. We understand that Total sulphur maximum limit is 10 PPM and H2S maximum limit is 5 PPM. Please confirm 14 Acceptable subjected to meeting PNGRB, other statutory requirements and tender conditions. All the consumables such as tape / carrier gas / calibration gas / other gas, etc. required for 2 years continuous We request to accept Aluminium oxide based Moisture analyzer. We had online operation is in bidder's scope. Further, all the Moisture analyzer supplied the same in ONGC, EIL, Toyo etc. project. Request to please items / accessories as required considering OEM Technical confirm recommendations for installation in all respect shall also be provided by bidder. However, analyzers, probes & tappings shall be separate for each H2S. Total Sulphur, Gas Chromatograph and moisture analyzer. 15 GC controller are part of analyzer and are suitable for hazardous area and Acceptable subjected to meeting rest of the tender Technical GC Controller supplied in many GAIL project, hence we understand that GC controller conditions. mounted in field is also acceptable. 16 As per P&ID, we understand that single tapping is required in skid for all type Analyzers, probes & tappings shall be separate for P&ID of USM skid with Analyzer of analyzer (i.e. GC. H2S+TS and moisture). each H2S. Total Sulphur, Gas Chromatograph and This tapping required 20D straight length. Please confirm moisture analyzer. 17 As per the process parameter inlet and outlet pressure difference is 3 kg/cm2. For desining of skid with pressure reduction we need minimum 5 kg/cm2 P&ID (USM) - NRL Section-1 Tender Condition Prevails. difference between inlet and outlet of PRS. Request to please provide pressure range accordingly. 18 As per Note-1 in vendor list, we understand that GAIL & MECON will accept Technical Vendor list vendor other than the given list based on the proven track record as per Note- Tender Condition Prevails. 1. Please confirm



REPLY TO BIDDERS QUERIES ANNUAL RATE CONTRACT 2(TWO) YEARS BASIS FOR

SUPPLY & INSTALLATION OF METERING SKIDS &



ASSOCIATED FACILITIES UNDER NORTH EAST GAS GRID PIPELINE PROJECT OF M/s IGGL Tender Doc. No.: 05/51/23VC/IGGL/030

					DATED: 10.03.2023	
S.N.	CL. No.	Section/ Page	Section Detail/Description	Clarification / Deviation	MECON's Reply	
19		Technical	Wet calibration alongwith meter run	We understand that project specific meter run need to be sent to lab for calibration (upstream 10D + Flow profiler + 10D and Downstream 5D). Spool and profiler available in lab should not use for calibration.	Tender Condition Prevails.	
20		Commercial	Delivery Period	We request delivery of 12 months due to Longer waiting period for all Third Party Labs across the globe including GAIL Hazira lab Calibration slot & 3.2 Certification requirement. Further transportation to the site in North East India will take weeks	Tender Condition Prevails.	
21		Commercial	Bidding / Evaluation	1. As per EMD value, there is common EMD for complete GROUP A, individual SOR wise (SOR A1, A2, A3, A4 & A5) EMD value is not given. We understand that evaluation is Group wise. There are two group in this tender GROUP A & GROUP B. Hence we understand that bidder has to bid for complete Group only. Individual skid shall not be bid by bidder.	Bidder understanding is corrcet .	
22		Commercial	Bid Datasheet	As per the BDS point no. 40, Each group is non-split able or not-divisible. Hence request to please confirm whether each line item / skid within each Group A / Group B is individually splitable to MSE and non MSE bidder. Please confirm	Tender Condition Prevails.	